



NYS Department of Corrections and Community Supervision IFB #2019-24 Gym Heating Project Questions and Answers

1. Q: What size, type, brand, and voltage of new ceiling unit ventilators are needed?
A: **Trane model huv 115v, 41.2 mbh.**
2. Q: What size, type, brand and voltage of new circulating pump is needed?
A: **Bell & Gossett 1 ½", 115v**
3. Q: What is the size of the lines that are needed to feed new ventilators, control valves, shut offs and circuit setters?
A: **1"**
4. Q: Do we build new chases for piping and wiring or find existing HWS and HWR lines about the ceiling that we can tie into?
A: **Use existing lines above ceiling.**
5. Q: What size, type and thickness of insulation on HWS and HWR piping in the ceiling is needed?
A: **1"-1 ½" fiberglass piping insulation**
6. Q: Will unit ventilators need dampers or are they built in?
A: **Will require 24" X 24" X 6" fixed outside air louvers.**
7. Q: Are any new controls, control wiring needed or need to be relocated?
A: **Wiring and controls for circulating pump and thermostat for unit ventilators with cage.**
8. Q: Does wiring about the ceiling need to be in conduit or mc cable?
A: **M/C cable is sufficient.**
9. Q: Do we put the plating on the outside wall under the window wall up to the bottom of the window masonry?



Corrections and Community Supervision

ANDREW M. CUOMO
Governor

ANTHONY J. ANNUCCI
Acting Commissioner

A: **Yes**

10.Q: Is there specifications for the vulcanized rubber mats material?

A: **48" X 72" X 5/8"**

11.Q: Does the gym floor currently have rubber mats on it now?

A: **Yes, (weight room only)**

12.Q: If there are mats currently in the gym, will they get turned over to the facility to be repurposed or removed off site?

A: **Turned over to Facility.**

13.Q: Does the entire gym floor need to be covered with mats?

A: **(Weight room only)**

14.Q: Who is responsible for removing & reinstalling the weight equipment from the gym?

A: **Facility**