

Annual Drinking Water Quality Report for 2023
City of Hudson
520 Warren Street, Hudson, NY 12534
(Public Water Supply Identification Number NY1000239)

INTRODUCTION

To comply with State regulations, the City of Hudson will be annually issuing a report describing the quality of your drinking water. The purpose of this report is to raise your understanding of drinking water and awareness of the need to protect our drinking water sources. Last year, your drinking water met all State drinking water health standards. This report is a snapshot of last year's water quality. Included are details about where your water comes from, what it contains, and how it compares to New York State standards. Our constant goal is and always has been, to provide to you a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and to protect our water resources. If you have any questions concerning this report or concerning your drinking water please contact: *Mr. George Topple, Jr., Chief Water Treatment Plant Operator, City of Hudson Water Treatment Plant, 520 Warren Street, Hudson, NY 12534; Telephone (519) 828-9458 or dpwclerk@cityofhudson.org*

We want our valued customers to be informed about their water service. If you want to learn more, please attend any of our regularly scheduled Town Board meetings. They are held on the 3rd Tuesday of each month at City Hall, call for times.

WHERE DOES OUR WATER COME FROM?

The City of Hudson's water source is a clean and plentiful surface water reservoir located in Churchtown, New York. Water is treated with sodium permanganate as it leaves Churchtown Reservoir for iron, manganese and organic precursor removal. The treatment process at the Hudson WTP consists of; coagulation using poly aluminum chloride to cause small particles to stick together when the water is mixed, making larger heavier particles; sedimentation allows the newly formed larger particles to settle out naturally; The flocculation process is enhanced with the addition of a nonionic polyacrylamide polymer; the water is clarified in a upflow adsorption clarifier and then filtration removes smaller particles by trapping them on a mixed media filter; final post chlorination to maintain a chlorine residual in the distribution system to prevent bacterial contamination; the pH of the filtered water is adjusted with a 25% solution of liquid caustic soda and zinc orthophosphate is also added for corrosion control.

In general, the sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activities. Contaminants that may be present in source water include microbial contaminants; inorganic contaminants; pesticides and herbicides; organic chemical contaminants; and radioactive contaminants. In order to ensure that tap water is safe to drink, the State and EPA prescribe regulations, which limit the amount of certain contaminants in water, provided by public water systems. The State Health Department's and the FDA's regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

FACTS AND FIGURES

Our water system provides water through 2,200 service connections to the entire population of 6,713 residents in the City of Hudson. In 2023 the city water system produced 375,310,000 gallons of water. Our average daily demand is 983,000 gallons. Our single highest day was 1,160,000 gallons. Because the majority of residential accounts are unmetered, there is no clear record of the total water consumed and billed. A recent study performed for the City estimated the unbilled water is 20% of the water produced. The unbilled water is used to flush transmission and distribution mains, for fighting fires or is lost through the distribution system. The annual charge for a residential customer was \$420.00 per unit for combined water/sewer.

ARE THERE CONTAMINANTS IN OUR DRINKING WATER?

In accordance with State regulations, the City of Hudson routinely monitors your drinking water for numerous contaminants. We test your drinking water for inorganic contaminants, radiological contaminants, lead and copper, nitrate, volatile organic contaminants, and synthetic organic contaminants. In addition, we test 9 samples for coliform bacteria each month. The table presented on page 3 depicts which contaminants were detected in your drinking water. The state allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. Some of the data, though representative of the water quality, is more than one year old and is noted. For a listing of the parameters we analyzed that were not detected along with the frequency of testing for compliance with the NYS Sanitary Code, see Appendix A.

It should be noted that all drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily pose a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline (800-426-4791) or the Columbia County Public Health Services at (519) 828-3358.

WHAT DOES THIS INFORMATION MEAN?

As you can see by the table on page 3, our system had no violations. We have learned through our testing that some contaminants have been detected; however, these compounds were detected below New York State requirements.

New York State has adopted the first in the nation drinking water standard for 1,4-Dioxane along with one of the lowest maximum contaminant levels for PFOA and PFOS. Public Water Supplies in NYS are required to test for PFOA, PFOS and 1,4-Dioxane. PFOA and PFOS have Maximum Contaminant Levels (MCL) of 10 parts per trillion each while 1,4-Dioxane has an MCL of 1.0 parts per billion. The City of Hudson Water Department has completed its 1st quarter 2023 monitoring with no detects for PFOA, PFOS & 1,4-Dioxane.

IS OUR WATER SYSTEM MEETING OTHER RULES THAT GOVERN OPERATIONS?

During 2023, our system was in compliance with applicable State drinking water operating, monitoring and reporting requirements.

DO I NEED TO TAKE SPECIAL PRECAUTIONS?

Some people may be more vulnerable to disease causing microorganisms or pathogens in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice from their health care provider about their drinking water. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium*, *Giardia* and other microbiological pathogens are available from the Safe Drinking Water Hotline (800-426-4791).

When operated under appropriate conditions, commonly used filtration technologies such as ours can effectively remove *Giardia* cysts from water. The highest removal by granular filters is achieved when coagulation is optimized. EPA's Surface Water Treatment Rule requires public water systems such as ours so we can insure 99.9% *Giardia* removal.

INFORMATION ON LEAD

Lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The City of Hudson is responsible for providing high quality drinking water and removing lead pipes, but cannot control the variety of materials used in plumbing components in your home. You share the responsibility for protecting yourself and your family from the lead in your home plumbing. You can take responsibility by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Before drinking tap water, flush your pipes for several minutes by running your tap, taking a shower, doing laundry or a load of dishes. You can also use a filter certified by an American National Standards Institute accredited certifier to reduce lead in drinking water. If you are concerned about lead in your water and wish to have your water tested, contact the City of Hudson Water Department. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <http://www.epa.gov/safewater/lead>.

WATER CONSERVATION TIPS

The City of Hudson encourages water conservation. There are a lot of things you can do to conserve water in your own home. Conservation tips include:

- ◆ Only run the dishwasher and clothes washer when there is a full load
- ◆ Use water saving showerheads
- ◆ Install faucet aerators in the kitchen and the bathroom to reduce the flow from 4 to 2.5 gallons per minute
- ◆ Water gardens and lawn for only a couple of hours after sunset
- ◆ Check faucets, pipes and toilets for leaks and repair all leaks promptly
- ◆ Take shorter showers

CAPITAL IMPROVEMENTS

In 2023 there were no major modifications made to the treatment plant or distribution system .

CITY OF HUDSON TABLE OF DETECTED CONTAMINANTS							
Public Water Supply Identification Number NY1000239							
Contaminant	Violation Yes/No	Date of Sample	Level Detected	Unit Measurement	MCLG	Regulatory Limit (MCL, TT or AL)	Likely source of Contamination
Microbiological Contaminants							
Turbidity ¹ (Highest turbidity sample)	N	9/8/23	0.14 ¹	NTU		TT=1.0 NTU	Soil runoff
			100%			TT= 95% of samples <0.3 NTU	
Inorganic Contaminants							
Chloride	N	1/25/23	33.1	mg/l	N/A	MCL=250	Erosion of natural deposits
Chromium	N	1/25/23	1.8	µg/l	100	MCL=100	Erosion of natural deposits.
Copper Range of copper concentration	N	7/13/22- 7/26/22	0.0800 ¹ 0.0098-0.117	mg/l	1.3	AL=1.3	Corrosion of household plumbing systems
Lead Range of lead concentration	N	7/13/22- 7/26/22	1.0 ² ND-3.2	µg/l	N/A	MCL=15	Corrosion of household plumbing systems, erosion of natural deposits
Manganese	N	1/25/23	2.92	µg/l	N/A	MCL=300	Naturally occurring;
Nitrate	N	1/25/23	0.264	mg/l	10	MCL=10	Erosion of natural deposits
pH	N	1/25/23	7.78	units	N/A	NA	6.5-8.5
Sodium ⁴	N	1/25/23	22.7	mg/l	N/A	N/A ³	Naturally occurring; Road salt; Water softeners; Animal waste
Sulfate	N	1/25/23	9.60	mg/l	N/A	MCL=250	Geology
Zinc	N	1/25/23	249	µg/l	N/A	MCL=5000	Naturally occurring;
Total Organic Carbon							
Raw Water Treated Water	N	Jan-Dec 2023	2.4-5.7 1.28-2.2	mg/l	N/A	TT	Organic material both natural and man made; Organic pollutants, decaying vegetation.
Synthetic Organic Chemicals							
PFBA	N	9/26/23	4.11	ng/l	N/A	MCL=10 ^{7,8,9}	Released into the environment from widespread use in commercial and industrial applications
Dalapon	N	11/2/23	1.09	µg/l	N/A	MCL=50	Runoff from herbicide used on rights of way.
Disinfection Byproducts (Quarterly samples)							
Haloacetic Acids (HAA5) ⁵ Average Range of values for HAA5 (Train Station)	N	2/16/23	31.9	µg/l	N/A	MCL=60	By-product of drinking water chlorination
		5/17/23	13.5-51.1				
Total Trihalomethanes (TTHM) Average Range of values for TTHM (Train Station)	N	8/17/23	47.5	µg/l	N/A	MCL=80	By-product of drinking water chlorination
		11/9/23	24.3-82.7				
Haloacetic Acids (HAA5) ⁵ Average Range of values for HAA5 (Water Pollution Control)	N	2/16/23	33.4	µg/l	N/A	MCL=60	By-product of drinking water chlorination
		5/17/23	15.8-49.9				
Total Trihalomethanes (TTHM) Average Range of values for TTHM (Water Pollution Control)	N	8/17/23	48.4	µg/l	N/A	MCL=80	By-product of drinking water chlorination
		11/9/23	30.4-76.2				
Chlorine Residual (average) range	N	Daily	1.76	ppm	MRDLG	MRDL	Water additive used to control microbes
			1.37-2.05		N/A	MCL=4	

Notes:

1. Turbidity is a measure of the cloudiness of the water. We monitor it because it is a good indicator of the effectiveness of our filtration system. Our highest single turbidity measurement (0.14) for the year occurred on 9/8/23. State regulations require that turbidity must always be below 1.0 NTU. The regulations require that 95% of the turbidity samples collected have measurements below 0.3 NTU. We met that requirement 100% of the time. Distribution system turbidity is performed weekly with 1.48 NTU being the highest level detected. Our average distribution turbidity was 0.22 NTU.
2. The level presented represents the 90th percentile of the 20 test sites. A percentile is a value on a scale of 100 that indicates the percent of a distribution that is equal to or below it. The 90th percentile is equal to or greater than 90% of the copper values detected at your water system. In this case, 20 samples were collected at your water system and the 90th percentile value was the sample with the third highest value (level detected 0.08 mg/l). The action level for copper was not exceeded at any of the sites tested.
3. The level presented represents the 90th percentile of 20 test sites. The action level for lead was not exceeded at any of the 20 sites tested
4. Water containing more than 20 mg/l should not be consumed by persons on severely restricted sodium diets.
5. The average is based on a Locational Running Annual Average (LRAA). The average shown is the highest LRAA for 2022. The highest LRAA for the Train Station was the 1st quarter for the TTHMs and 1st quarter for the HAA5s. For the Water Pollution Control STP the highest LRAA was in the 1st quarter for the TTHMs and the 1st quarter for the HAA5s.
6. The Interim Enhanced Surface Water Treatment Rule (IESWTR) requires monitoring of raw and finished water Total Organic Carbon (TOC). Depending on the raw water alkalinity value, proper water treatment should remove between 15% to 45% of the raw water TOC thus reducing the amount of disinfection byproducts produced.
7. The MCL of 10 ng/l is only for PFOA and PFOS.
8. All perfluoroalkyl substances, besides PFOA and PFOS, are considered Unspecified Organic Contaminants (UOC) which have an MCL = 0.05 mg/L.
9. USEPA Health Advisory Levels identify the concentration of a contaminant in drinking water at which adverse health effects and/or aesthetic effects are not anticipated to occur over specific exposure durations. Health Advisory Levels are not to be construed as legally enforceable federal standards and are subject to change as new information becomes available. PFBS and HFPO-DA also have Health Advisory Levels

Non-Detects (ND) - laboratory analysis indicates that the constituent is not present.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter (µg/l) - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

Parts per trillion (ppt) or Nanograms per liter (nanograms/l) (ng/l) - one part per trillion corresponds to one minute in 2,000,000 years, or a single penny in \$10,000,000,000.

Nephelometric Turbidity Unit (NTU) - nephelometric turbidity unit is a measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person.

90th Percentile Value- The values reported for lead and copper represent the 90th percentile. A percentile is a value on a scale of 100 that indicates the percent of a distribution that is equal to or below it. The 90th percentile is equal to or greater than 90% of the lead and copper values detected at your water system

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Treatment Technique (TT) -A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

Maximum Contaminant Level - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal - The "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contamination.

Locational Running Average (LRA): The LRA is calculated by taking the average of the four most recent samples collected at each individual site.

N/A-not applicable

CLOSING

Thank you for allowing us to continue providing your family with clean, quality water this year. In order to maintain a safe and dependable water supply we sometimes need to make improvements that will benefit our customers. We ask that all our customers help us protect our water sources, which are the heart of our community. Please call our office if you have questions.

**City of Hudson
PWSID 1000239
Source Water Assessment Summary**

The NYSDOH has completed a source water assessment for this system, based on available information. Possible and actual threats to this drinking water source were evaluated. The state source water assessment includes a susceptibility rating based on the risk posed by each potential source of contamination and how easily contaminants can move through the subsurface to the wells. The susceptibility rating is an estimate of the potential for contamination of the source water, it does not mean that the water delivered to consumers is, or will become contaminated. See section "Are there contaminants in our drinking water?" for a list of the contaminants that have been detected, if any. The source water assessments provide source managers with additional information for protecting source waters into the future.

The source water assessment has rated the Churchtown Reservoir as having a medium-high susceptibility to microbial and phosphorus, and a low rating to organics, industrial solvents, nitrates and other industrial contaminants. Land cover and its associated activities within the assessment area does not increase the potential for contamination. No permitted discharges are found in the assessment area. There is also noteworthy contamination susceptibility associated with other discrete contaminant sources, and these facility types include: mines. It should be noted that hydrologic characteristics (e.g. basin shape and flushing rates) generally make reservoirs highly sensitive to existing and new sources of phosphorus and microbial contamination.

The county and state health departments will use this information to direct future source water protection activities. These may include water quality monitoring, resource management, planning and education programs. A copy of the assessment can be obtained by contacting us.

Appendix A

New York State Sanitary Code Compliance Monitoring Requirements- Compounds Analyzed that were Below Limits of Detection

CITY OF HUDSON TEST RESULTS						
Public Water Supply Identification Number NY1000239						
CONTAMINANT	MONITORING FREQUENCY		CONTAMINANT	CONTAMINANT	MONITORING FREQUENCY	
Asbestos	Every 9 years Sample from 5/11/21		POC's (Volatile Organic Compounds)			
			Benzene	Trans-1,3-Dichloropropene	2/24/23 NON-DETECT	
Antimony	Monitoring requirement is one sample annually		Bromobenzene	Ethylbenzene		
Arsenic			Bromochloromethane	Hexachlorobutadiene		
			Bromomethane	Isopropylbenzene		
Beryllium			N-Butylbenzene	p-Isopropyltoluene		
Cadmium			sec-Butylbenzene	Methylene Chloride		
Chromium		Sample results from 2/24/23		Tert-Butylbenzene		n-Propylbenzene
Cyanide				Carbon Tetrachloride		Styrene
Mercury				Chlorobenzene		1,1,1,2-Tetrachloroethane
Nickel				2-Chlorotoluene		1,1,2,2-Tetrachloroethane
Selenium				4-Chlorotoluene		Tetrachloroethene
Thalium				Dibromomethane		Toluene
				1,2-Dichlorobenzene		1,2,3-Trichlorobenzene
				1,3-Dichlorobenzene		1,2,4-Trichlorobenzene
			1,4-Dichlorobenzene	1,1,1-Trichloroethane		
			Dichlorodifluoromethane	1,1,2-Trichloroethane		
			1,1-Dichloroethane	Trichloroethene		
		1,2-Dichloroethane	Trichlorofluoromethane			
Silver	Monitoring requirement is at State discretion		1,1 Dichloroethene	1,2,3-Trichloropropane		
Iron			cis-1,2 Dichloroethene	1,2,4-Trimethylbenzene		
Manganese			Trans-1,2-Dichloroethene	1,3,5-Trimethylbenzene		
Color		Sample results from 2/24/23		1,2 Dichloropropane		m-Xylene
				1,3 Dichloropropane		o-Xylene
				2,2 Dichloropropane		p-Xylene
				1,1 Dichloropropene	Vinyl Chloride	
		Cis-1,3-Dichloropropene				
			Total Coliform / E. coli		Monitoring is 9 samples/ month NON-DETECT	
			Radiological Parameters			
			Gross Beta particle activity		requirement is one sample every 6-9 years Sample from 4/5/17 NON-DETECT	
			Radium 226 & 228			
Regulated & Unregulated Synthetic Organic Chemicals						
Synthetic Organic Chemicals (Group I)			Synthetic Organic Chemicals (Group II)		Monitoring requirement is every 18 months NON-DETECT Sample 4/5/22 ^State waiver does not require monitoring these compounds	
Alachlor	Aldicarb		Aldrin	Benzo(a)pyrene		
Aldicarb Sulfoxide	Aldicarb Sulfone		Butachlor	Carbaryl		
Atrazine	Carbofuran		Dalapon	Di(2-ethylhexyl)adipate		
Chlordane	Dibromochloropropane		Di(2-ethylhexyl)phthalate	Dicamba		
	Endrin		Dieldrin	Dinoseb		
Ethylene Dibromide	Heptachlor		Diquat*	Endothall*		
Lindane	Methoxythlor		Glyphosate*	Hexachlorobenzene		
PCB's	Toxaphene		Hexachlorocyclopentadiene	3-Hydroxycarbofuran		
2,4,5-TP (Silvex)	1,4-Dioxane*		Methomyl	Metolachlor		
1,4 Dioxane			Metribuzin	Oxamyl vydate		
			Pichloram	Propachlor		
			Simazine	2,3,7,8-TCDD (Dioxin)*		

